

OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR
Near Jarada Bunglow, Pin - 760004, Ph. 0680-2296344
eerwss_bam@nic.in rwssbam@gmail.com

No. 283^(Lab) /dt 04.11.2023
To

The Principal,
St. Xavier's High School,
Ambapua, Berhampur,
Dist. Ganjam (Odisha).

Sub : Water Quality Test Report of St. Xavier's High School.

Ref: Ltr No. SXHS/1902/2023 Dtd. 02.11.2023


Sir,


With reference to the water sample submitted by you at District Water Testing Laboratory, Berhampur, the following Parameters are tested.

Sl.No.	Parameter	Units	Permissible Limit	Testing Value
				Tap water
1	Alkalinity	Mg/ltr	600	88.0
2	Chloride	Mg/ltr	1000	72.0
3	Fluoride	Mg/ltr	1.5	0.415
4	Total Hardness	Mg/ltr	600	80.0
5	Iron	Mg/ltr	1.0	0.160
6	pH	--	6.5-8.5	7.01
7	Elec. Conductivity	(µmho/cm)	--	421.0
8	TDS	Mg/ltr	2000	273.65
9	Turbidity	NTU	5	2.60

Water is safe for Drinking because testing values are under permissible limit.

Kuna Bhuges
Jr. Lab Asst. 4.11.2023
DLL, Berhampur
Jr. Laboratory Assistant
Dist. Water Testing Laboratory
R.W.S. & S., Berhampur (Orissa)

Yours faithfully,

Executive Engineer (RWSS)
R.W.S. & S., Berhampur (Orissa)


PRINCIPAL
St. Xavier's High School Sr. Sec.
Berhampur (Ganjam)



Brahmapur Municipal Corporation (BeMC)

Ramlinga Road, Gandhi Nagar, Berhampur 760001, Odisha

ANNEXURE - C

Appendix - XIII

OFFICE OF THE HEALTH OFFICER, BERHAMPUR DIVISION, GANJAM, ODISHA

Letter No.: BeMC/HSS/23(2099)

Date: 07.11.2023

Certified that the drinking water facility at 'St. Xavier's High School, Senior Secondary, Ambapua, Berhampur, situated at Mouza - Ambapua, Tahsil - Berhampur, District - Ganjam', comprises of Three Blocks having sufficient drinking water facilities and are installed with quality satisfying water purifiers, water tanks are cleaned periodically. The water quality reports are also attached where all tests are thoroughly checked and certified at the laboratories and the sample was collected by officer from Health Department, BeMC, Berhampur division.

The inspection was headed by Mr. Tirupati Adhikari, Health Officer, Brahmapur Municipal Corporation (BeMC), Berhampur Division and inspected the water tanks at St. Xavier's High School Senior Secondary Ambapua, Opposite Income Tax Office, Ambapua Berhampur, Mouza - Ambapua, Tahasil - Berhampur, District - Ganjam, Odisha, 760010. The water test reports are satisfactory, toilets and campus is hygienic in Health point of view and all conditions are satisfactory as per the norms of Department of Health.

Certificate issued on 07.11.2023 at BeMC, Berhampur, Ganjam, Odisha.

Certificate is valid for period of Twelve Months (valid till - 06.11.2024)

Signature and Seal: -

Name of the issuing officer:- Tirupati Adhikari

Designation :- Health officer in-charge, dept of Health and Sanitation, BeMC, Berhampur, Gm

Note: This certificate should be signed /issued by Health Officer & above officer of concerned Government Department only.

U Patraik
PRINCIPAL

St. Xavier's High School Senior Secondary
BERHAMPUR (G.M.)

Assistant

Manager
St. Xavier's High School
Berhampur (G.M.)